



Betriebsdruck: 14 bar  
 Prüfdruck: 22 bar  
 Kernrohrdurchmesser: 9.52 mm  
 Rohrteilung: 25x22 oder 25x19

BG	A	B	C	D	E	Rp	RR	WW	Art.-Nr
							Heizen		
60	695	510	275	100	240	3/4"	3	6	65622
70	895	710	275	100	240	3/4"	3	8	65624
80	895	710	375	150	340	1"	3	11	65625
90	1095	910	375	150	340	1"	3	11	65626

Anzahl										
Stamm-Nr.	Stammteil-Nr.	KAMPMANN			Index	Änderung			Name	Datum
	Folge-Nr.	49794 Lingen Tel. 0591-7108-0								
Projekt-Nr.	Erst.	07.07.06	feye	Format	Art-Gr.	SAP-Nr.	CAD-Nr.	Vers.		
Auftr-Nr.	Änder.	12.07.06	feye	3	150		342717	1		
STL-Nr.	Gepr.	12.07.06	feye	Werkstoff	Nr.					
	Freig.	12.07.06	feye	M 1:4	Abm.	Zul.Abw. ISO 2768-m			Revision	
Wärmetauscher CuAl Heizen 3RR BG__										Betrieb
Airblock FG										Bl.